



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Crawford County
New Washington Dollar General
Construction Storm Water
Facility ID No. 2GC03244

November 30, 2012

Mr. Mark Bush
New Washington DG, LLC
361 Summit Boulevard, Suite 110
Birmingham, Alabama 35243

Dear Mr. Bush:

On November 21, 2012, I inspected the New Washington Dollar General, 308 South Kibler Street, New Washington. The purpose of my visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of the inspection, no earthwork was occurring and no construction equipment was present.

Your November 26, 2012, e-mail confirmed that construction activities will not start until December 2012. When construction does commence, please remember the permit requirements for storm water management during construction and post construction, such as weekly self-inspections and the requirement to apply cover within seven days on bare soil in any areas that will sit idle for more than 21 days. Your sediment controls must be installed within seven days of grubbing and before any grading.

Please send a written reply within 10 days of the date of this letter describing how the post construction storm water management requirements will be met. Your reply should include the type(s) of practices you are implementing and the basis for their design. If there are any questions, please contact me at 419-373-3009.

Sincerely,

Lynette Hablitzel, P.E.
Division of Surface Water
Storm Water Program

/jlm

ec: Tracking