



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Lucas County
Meinke Marina
NPDES Permit

November 30, 2012

Mr. Gary Meinke
Meinke Marina and Campground
10760 Jerusalem Road
Curtice, Ohio 43412

Dear Mr. Meinke:


On November 15, 2012, I conducted an inspection of the sewage treatment plant serving Meinke Marina West located at 10955 Corduroy Road, Jerusalem Township. During my inspection, the package plant was shut down for the season due to no flow into the plant. The regulated outfall pipe was not discharging.

Our records indicate that your facility's discharge had a chlorine residual limit exceedance in June and August 2012. Your non-compliance report indicated that you planned on reducing the chlorine dosage amount into the system in an effort to reduce the residual concentration. This action may compromise the E. coli bacteria removal and cause the discharge to violate the E. coli limit. Your treatment system should be modified to include a de-chlorination unit that is typically used for chlorine residual removal in systems similar to yours. Please note that addition a de-chlorination unit will require a Permit to Install (PTI) from Ohio EPA prior to construction.

For the purpose of reporting, please note that the "No Discharge" check box on the eDMR data entry form should be selected (and PIN the eDMR) until a discharge occurs.

If you have any questions regarding the above, please contact me at naajy.abdullah@epa.state.oh.us or (419) 373-3017.

Sincerely,


Naajy Abdullah, P.E.
Division of Surface Water

/jlm
Enclosure
ec: Tracking

NPDES COMPLIANCE INSPECTION REPORT

Section A: National Data System Coding

Permit #	NPDES	Yr/Mo/Day	Inspection Type	Inspector	FacType
2PR00165	OH0130290	12/11/15	C	S	2

Section B: Facility Data

Name and Location of Facility Inspected Meinke Marina West 10995 Corduroy Road Curtice, Ohio 43412	Entry Time	Permit Effective Date
	10:00 a.m.	6/1/2012
	Exit Time	Permit Expiration Date
	10:30 a.m.	5/31/2016

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Gary Meinke, Owner	(419) 836-7774

Name, Address and Title of Responsible Official	Phone Number
Same as above	

Section C: Areas Evaluated During Inspection (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

<input checked="" type="checkbox"/> S Permit	<input checked="" type="checkbox"/> S Flow Measurement	<input checked="" type="checkbox"/> N Pretreatment
<input checked="" type="checkbox"/> M Records/Reports	<input checked="" type="checkbox"/> N Laboratory	<input checked="" type="checkbox"/> N Compliance Schedules
<input checked="" type="checkbox"/> S Operations & Maintenance	<input checked="" type="checkbox"/> S Effluents	<input checked="" type="checkbox"/> M Self-Monitoring Program
<input checked="" type="checkbox"/> S Facility Site Review	<input checked="" type="checkbox"/> N Sludge Storage/Disposal	<input type="checkbox"/> Other

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

* Plant was shut down for winter due to no flow.

 Naajy Abdullah, P.E. Name(s) and Signature(s) of Inspector(s)	11/20/12 Date	Ohio EPA, <u>Northwest</u> District Office
---	------------------	---

 Tom Poffenbarger, P.E. Name and Signature of Reviewer	11/26/12 Date	Ohio EPA, <u>Northwest</u> District Office
---	------------------	---