



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Wood County
Five Point Road MHP WWTP
Ohio EPA Permit No. 2PY00073*AD
NPDES Permit No. OH0141615

November 14, 2012

Ms. Michelle Myers, Owner
Five Point MHP
24730 State Route 199
Perrysburg, Ohio 43551

Dear Ms. Myers:

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Five Point Road Mobile Home Park (MHP) Wastewater Treatment Plant (WWTP) shows that this facility is in significant non-compliance (SNC) for the following parameters at outfall number 001: Ammonia and Chlorine. I am enclosing a list of violations for this facility for the period of July 1, 2012, through September 30, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare. When a facility is in SNC, Ohio EPA will consider escalated enforcement action

You sent an email on August 27, 2012, that you would be wasting sludge and adding nutrients to address the ammonia problems. You have not had any ammonia violations in August or September 2012. If this action did correct the violations, you will need to continue to waste on a regular basis before your WWTP incurs violations. Your WWTP also had violations for chlorine. While the disinfection season is over, you will need to be diligent in making sure that you have adequate chlorine and dechlorination tablets in use at all times. If you continue to violate your NPDES permit, we will be forced to initiate enforcement action.

If you wish to meet with us to discuss this matter, please contact me at 419-373-3016 within 10 days of receiving this letter in order to set up a meeting. You may wish to share this letter with your contract operator.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm

Enclosure

cc: Thomas Poffenbarger, DSW-NWDO
Tracking

Compliance Data for Five Point MHP between 7/1/2012 to 10/1/2012

Summary

Permit Effluent Limit Violations: 6

Permit Effluent Code Violations: 0

Permit Effluent Frequency Violations: 2

Compliance Schedule Violations: 0

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2012	001	Nitrogen, Ammonia (NH3)	30D Conc	1.5	3.225	7/1/2012
July 2012	001	Nitrogen, Ammonia (NH3)	1D Conc	2.2	2.45	7/2/2012
July 2012	001	Nitrogen, Ammonia (NH3)	1D Conc	2.2	4.	7/31/2012
July 2012	001	Fecal Coliform	1D Conc	2000	2600.	7/31/2012
August 2012	001	Chlorine, Total Residu	1D Conc	0.019	.08	8/14/2012
August 2012	001	Chlorine, Total Residu	1D Conc	0.019	.08	8/28/2012

Frequency Violations						
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
July 2012	001	Water Temperature	1/Week	1	0	7/8/2012
July 2012	001	Dissolved Oxygen	1/Week	1	0	7/8/2012