



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 13, 2012

Re: Washington County
R&J Trucking Company
Industrial Storm Water
0GR00427*DG

Mr. Dennis Coe
14530 S.R. 7
Marietta, Ohio 45750

Dear Mr. Coe:

On October 23, 2012, I conducted an inspection of your facility. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. As a result of the inspection, I have the following comments:

The General Industrial Storm Water permit states:

2.1.2 Control Measures/Best Management Practices (BMPs).

2.1.2.1 Minimize Exposure. You shall minimize the exposure of manufacturing, processing, and material storage areas (including loading and unloading, storage, disposal, cleaning, maintenance, and fueling operations) to rain, snow, snowmelt, and runoff by either locating these industrial materials and activities inside or protecting them with storm resistant coverings (although significant enlargement of impervious surface area is not recommended). In minimizing exposure, you should pay particular attention to the following:

- use grading, berming, or curbing to prevent runoff of contaminated flows and divert run-on away from these areas;
- locate materials, equipment, and activities so that leaks are contained in existing containment and diversion systems (confine the storage of leaky or leak-prone vehicles and equipment awaiting maintenance to protected areas);
- clean up spills and leaks promptly using dry methods (e.g., absorbents) to prevent the discharge of pollutants;
- use drip pans and absorbents under or around leaky vehicles and equipment or store indoors where feasible;

- use spill/overflow protection equipment;
- drain fluids from equipment and vehicles prior to on-site storage or disposal;
- perform all cleaning operations indoors, under cover, or in bermed areas that prevent runoff and run-on and also that capture any overspray; and
- ensure that all wash water drains to a proper collection system (i.e., not the storm water drainage system).

The discharge of vehicle and equipment wash water, including tank cleaning operations, is not authorized by this permit. These wastewaters shall be covered under a separate NPDES permit, discharged to a sanitary sewer in accordance with applicable industrial pretreatment requirements, or disposed of otherwise in accordance with applicable law. Note: Industrial materials do not need to be enclosed or covered if storm water runoff from affected areas will not be discharged to receiving waters or if discharges are authorized under another NPDES permit.

2.1.2.2 Good Housekeeping. You shall keep clean all exposed areas that are potential sources of pollutants, using such measures as sweeping at regular intervals, keeping materials orderly and labeled, and storing materials in appropriate containers.

Remove the scrap metal from the back lot area behind the maintenance garage, clean up the diesel leak in the refueling area, and provide a spill kit in the refueling area.

Please correct the above violations and respond to me in writing within thirty days. In the letter, you should describe the actions taken to address the violations noted above.

Coll materials in Zanesville, Ohio will take your plastic related waste. They can be reached at (740) 452-5691.

If you have any questions, please contact me at (740) 380-5277.

Sincerely,



Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh