



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Balby, Director

December 4, 2012

Han Nguyen  
Keystone Construction, Incorporated  
2415 South High Street  
Columbus, OH 43207

**Re: Suburban Village / Pickaway County**

Dear Mr. Nguyen:

This letter is written in follow-up to a construction storm water inspection that I conducted on November 29, 2012, at the Suburban Village located at the corner of Jefferson Street and Station Street, in Ashville, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

**Sediment and Erosion Controls:**

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

ec: Greg Sanders, DSW/CDO

GS/nsm Suburban Village, November 29, 2012