



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 10, 2012

**Re:** Tuscarawas County  
Twin City WWTP  
Notice of Violation  
OPD00015, OH0020079  
Correspondence (PWW/Major)

Mr. John O'Hara, President of the Board  
Twin City Water and Sewer District  
308 Grant Street  
Dennison, Ohio 44621

Dear Mr. O'Hara:

We have received your self-monitoring reports covering the months of July through September 2012 for the Twin City WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	31648	E. coli	8/15/2012	7D Conc	362	627.183
001	31648	E. coli	8/8/2012	7D Conc	362	1017.71
001	31648	E. coli	8/1/2012	30D Conc	161	202.621

\* 1D Conc is equal to the daily maximum concentration limit.  
1D Qty is equal to the daily maximum loading limit.  
7D Conc is equal to the weekly average concentration limit.  
7D Qty is equal to the weekly average loading limit.  
30D Conc is equal to the monthly average concentration limit.  
30D Qty is equal to the monthly average loading limit.

A prior explanation of these violations has been sent. Please provide an update as to whether the UV system will be ready for the 2013 disinfection season.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in black ink, appearing to read "Tim Fulks", written in a cursive style.

Timothy A. Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Mr. Donnie Fawcett, Assistant Supt., Twin City Water & Sewer District