



John R. Kasich, Governor  
 Mary Taylor, Lt. Governor  
 Scott J. Nally, Director

December 10, 2012

**Re:** Guernsey County  
 Seneca Lake Campground  
 Notice of Violation  
 OPX00002; OH0059102  
 Correspondence (PWW)

Mr. Boris Slogar, Chief Engineer  
 Muskingum Watershed Conservancy District  
 1319 3rd Street, NW  
 P.O. Box 349  
 New Philadelphia, Ohio 44663

Dear Mr. Slogar:

We have received your self-monitoring reports covering the months of July through September 2012 for the Seneca Lake Lagoon wastewater facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	80082	CBOD 5 day	8/22/2012	1D Conc	15	20.
001	50060	Chlorine, Total Residual	9/30/2012	1D Conc	0.011	.07
001	50060	Chlorine, Total Residual	9/29/2012	1D Conc	0.011	.06
001	50060	Chlorine, Total Residual	9/26/2012	1D Conc	0.011	.09
001	50060	Chlorine, Total Residual	9/24/2012	1D Conc	0.011	.06
001	50060	Chlorine, Total Residual	9/10/2012	1D Conc	0.011	.09
001	50060	Chlorine, Total Residual	9/3/2012	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	9/1/2012	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	8/28/2012	1D Conc	0.011	.06
001	50060	Chlorine, Total Residual	8/27/2012	1D Conc	0.011	.07
001	50060	Chlorine, Total Residual	8/26/2012	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	8/24/2012	1D Conc	0.011	.08
001	50060	Chlorine, Total Residual	8/23/2012	1D Conc	0.011	.12
001	50060	Chlorine, Total Residual	8/22/2012	1D Conc	0.011	.15
001	50060	Chlorine, Total Residual	8/16/2012	1D Conc	0.011	.06
001	50060	Chlorine, Total Residual	8/15/2012	1D Conc	0.011	.07
001	50060	Chlorine, Total Residual	8/14/2012	1D Conc	0.011	.13
001	50060	Chlorine, Total Residual	8/13/2012	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	8/11/2012	1D Conc	0.011	.14

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	50060	Chlorine, Total Residual	8/8/2012	1D Conc	0.011	.16
001	50060	Chlorine, Total Residual	8/7/2012	1D Conc	0.011	.07
001	50060	Chlorine, Total Residual	8/6/2012	1D Conc	0.011	.13
001	50060	Chlorine, Total Residual	7/31/2012	1D Conc	0.011	.09
001	50060	Chlorine, Total Residual	7/30/2012	1D Conc	0.011	.1
001	50060	Chlorine, Total Residual	7/27/2012	1D Conc	0.011	.09
001	50060	Chlorine, Total Residual	7/26/2012	1D Conc	0.011	.1
001	50060	Chlorine, Total Residual	7/25/2012	1D Conc	0.011	.06
001	50060	Chlorine, Total Residual	7/24/2012	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	7/23/2012	1D Conc	0.011	.09
001	50060	Chlorine, Total Residual	7/22/2012	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	7/21/2012	1D Conc	0.011	.14
001	50060	Chlorine, Total Residual	7/20/2012	1D Conc	0.011	.07
001	50060	Chlorine, Total Residual	7/19/2012	1D Conc	0.011	.16
001	50060	Chlorine, Total Residual	7/18/2012	1D Conc	0.011	.08
001	50060	Chlorine, Total Residual	7/17/2012	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	7/13/2012	1D Conc	0.011	.08
001	50060	Chlorine, Total Residual	7/10/2012	1D Conc	0.011	.07
001	00300	Dissolved Oxygen	9/1/2012	1D Conc	6.0	3.91
001	00300	Dissolved Oxygen	8/31/2012	1D Conc	6.0	5.2
001	00300	Dissolved Oxygen	8/29/2012	1D Conc	6.0	3.59
001	00300	Dissolved Oxygen	7/10/2012	1D Conc	6.0	3.6
001	00300	Dissolved Oxygen	7/9/2012	1D Conc	6.0	1.67
001	00300	Dissolved Oxygen	7/7/2012	1D Conc	6.0	5.86
001	00610	Nitrogen, Ammonia (NH3)	9/4/2012	1D Conc	2.5	5.04
001	00610	Nitrogen, Ammonia (NH3)	9/4/2012	1D Qty	0.35	.45783
001	00610	Nitrogen, Ammonia (NH3)	9/1/2012	30D Conc	1.5	3.225
001	00610	Nitrogen, Ammonia (NH3)	9/1/2012	30D Qty	0.21	.24226
001	00610	Nitrogen, Ammonia (NH3)	8/15/2012	1D Conc	2.5	4.74
001	00610	Nitrogen, Ammonia (NH3)	8/1/2012	1D Conc	2.5	5.08
001	00610	Nitrogen, Ammonia (NH3)	8/1/2012	30D Conc	1.5	4.91
001	00610	Nitrogen, Ammonia (NH3)	7/17/2012	1D Conc	2.5	7.99
001	00610	Nitrogen, Ammonia (NH3)	7/1/2012	30D Conc	1.5	4.29
001	00665	Phosphorus, Total (P)	9/4/2012	1D Conc	1.5	3.11
001	00665	Phosphorus, Total (P)	9/4/2012	1D Qty	0.21	.28251
001	00665	Phosphorus, Total (P)	9/1/2012	30D Conc	1.0	3.11
001	00665	Phosphorus, Total (P)	9/1/2012	30D Qty	0.14	.28251
001	00665	Phosphorus, Total (P)	7/1/2012	30D Conc	1.0	1.22
001	00400	pH	8/22/2012	1D Conc	6.5	5.85
001	00400	pH	7/9/2012	1D Conc	6.5	3.44
001	00665	Phosphorus, Total (P)	4/2/2012	1D Conc	1.5	2.16

\* 1D Conc is equal to the Daily Maximum concentration limit  
1D Qty is equal to the daily maximum loading limit.  
7D Conc is equal to the weekly average concentration limit.  
7D Qty is equal to the weekly average loading limit.  
30D Conc is equal to the monthly average concentration limit.  
30D Qty is equal to the monthly average loading limit

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

For the review period of April through September 2012, this facility was in significant non-compliance with its limits for pH, ammonia nitrogen, phosphorus, and chlorine. In a letter following an inspection I completed on August 8, 2012, I requested MWCD submit a plan to make the necessary improvements to come into compliance. The letter requested the plan be submitted within thirty (30) days or the facility would be referred for enforcement action. The inspection report was received by MWCD on August 13, 2012, as verified by the certified mail receipt. To date, no plan has been submitted and the facility has been referred for enforcement action.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Gary Taylor, Operator, MWCD