



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 16, 2012

Matthew Hannahs
Tab Construction Company Inc.
530 Walnut Avenue NE
Canton, Ohio 44708

**Re: Storm Water Inspection at Newark Processing- Licking County
Permit # 4GC03687**

Dear Mr. Hannahs:

This letter is written in follow-up to a construction storm water inspection I conducted, at Newark Processing located at 1367 East Main Street, Newark, Ohio on November 14, 2012. The purpose of the inspection was to evaluate compliance with Ohio EPA's General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- It appears area construction is complete. I noted the site was becoming established with a vegetative cover. Please understand successful vegetation is measured by a minimum density of 70 percent.
- At the time of the inspection, I was unable to evaluate the entire site due to restricted access. Please contact me upon receipt of this letter to schedule a final storm water inspection.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Newark Processing Licking County 11-14-2012



Figure 1 Silt fence requires maintenance