



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 3, 2012

Nathan Coey
City of Pataskala
621 W Broad Street Suite 1-D
Pataskala, Ohio 43062

Re: Notice of Termination Inspection at Utility installation on Vine, Cedar, Front, and High Streets in Pataskala, Ohio on November 26, 2012, Permit Number 4GC03782*AG

Dear Mr. Coey:

This letter is written in follow up to a construction storm water inspection I conducted of the utility installations associated with Vine, Cedar, Front, and High Streets in Pataskala, Ohio on November 26, 2012 in Pataskala, Ohio. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination form is required provided the following items are addressed:

- All areas must be protected from erosion measured by a minimum vegetative density of 70 percent for all disturbed areas.
- Once the vegetative requirements above are met please submit your Notice of Termination (NOT) concurrent with your submittal of the post construction verification. The NOT form can be found at: http://www.epa.state.oh.us/portals/35/documents/NOT_app_fis.pdf

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office^{HK/nsm}

Pataskala Utilities 11-26-2012