



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 11, 2012

Re: Noble County
Seneca Lake Baptist Assembly
Notice of Violation
OGS00057 OHGS00105
Correspondence (PWW)

Mr. Scott Seder
Seneca Lake Baptist Assembly
55819 Skyline Drive
Senecaville, Ohio 43708

Dear Mr. Seder:

We have received your self-monitoring reports covering the months of July through September 2012 for the Seneca Lake Baptist Assembly wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
3	00530	Total Suspended Solids	9/1/2012	30D Conc	12	14.

- * 1D Conc is equal to the daily maximum concentration limit.
- 1D Qty is equal to the daily maximum loading limit.
- 7D Conc is equal to the weekly average concentration limit.
- 7D Qty is equal to the weekly average loading limit.
- 30D Conc is equal to the monthly average concentration limit.
- 30D Qty is equal to the monthly average loading limit.

A prior explanation of these violations has been sent and no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in black ink, appearing to read "Tim Fulks". The signature is written in a cursive style with a large initial "T" and a long, sweeping underline.

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: David Mitchell