



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 11, 2012

**Re:** Noble County  
Caldwell WWTP  
Notice of Violation  
0PB00005; OH0020559  
Correspondence (PWW)

Mayor and Council  
Village of Caldwell  
Railroad Street  
Caldwell, Ohio 43724

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of July through September 2012 for the Caldwell WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00400	pH	9/15/2012	1D Conc	6.5	6.48
001	00400	pH	9/14/2012	1D Conc	6.5	6.34
001	00400	pH	8/22/2012	1D Conc	6.5	6.26
001	00400	pH	8/21/2012	1D Conc	6.5	6.12

- \* 1D Conc is equal to the daily maximum concentration limit.
- 1D Qty is equal to the daily maximum loading limit.
- 7D Conc is equal to the weekly average concentration limit.
- 7D Qty is equal to the weekly average loading limit.
- 30D Conc is equal to the monthly average concentration limit.
- 30D Qty is equal to the monthly average loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Timothy A. Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Mr. Arthur Schockling, Superintendent, Village of Caldwell