



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

December 11, 2012

**Re:** Guernsey County  
Coventry Estates I  
Notice of Violation  
OPG00010; OH0050393  
Correspondence (PWW)

Guernsey County Board of Commissioners  
627 Wheeling Avenue  
Suite 300  
Cambridge, Ohio 43725-2251

Dear Board of Commissioners:

We have received your self-monitoring reports covering the months of July through September 2012 for the Coventry Estates I wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type	Limit	Reported
001	00610	Nitrogen, Ammonia (NH3)	7/8/2012	7D Conc	3.0	5.8
001	00610	Nitrogen, Ammonia (NH3)	7/11/2012	30D Conc	2.0	2.95


- \* 1D Conc is equal to the Daily Maximum concentration limit.
- 1D Qty is equal to the daily maximum loading limit.
- 7D Conc is equal to the weekly average concentration limit.
- 7D Qty is equal to the weekly average loading limit.
- 30D Conc is equal to the monthly average concentration limit.
- 30D Qty is equal to the monthly average loading limit

A prior response to these explanations was submitted on August 23, 2012. No further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in black ink, appearing to read "Timothy A. Fulks". The signature is stylized with a large initial "T" and a long, sweeping underline.

Timothy A. Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Dennis Daughtery, Plant Operator