



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 11, 2012

Re: Guernsey County
Mental Health Center
Notice of Violation
OPH00013; OH0107727
Correspondence (PWW)

Guernsey County Board of Commissioners
627 Wheeling Avenue
Suite 300
Cambridge, Ohio 43725-2251

Dear Board of Commissioners:

We have received your self-monitoring reports covering the months of July through September 2012 for the Mental Health Center wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type	Limit	Reported
001	00530	Total Suspended Solids	7/1/2012	30D Conc	30	36.

- * 1D Conc is equal to the Daily Maximum concentration limit.
- 1D Qty is equal to the daily maximum loading limit.
- 7D Conc is equal to the weekly average concentration limit.
- 7D Qty is equal to the weekly average loading limit.
- 30D Conc is equal to the monthly average concentration limit.
- 30D Qty is equal to the monthly average loading limit

A prior response to these explanations was submitted on August 23, 2012. No further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in black ink, appearing to read 'Tim Fulks', written in a cursive style.

Timothy A. Fulks
District Representative
Division of Surface Water

TF/dh

c: Dennis Daughtery, Plant Operator