



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

December 11, 2012

Re: Guernsey County
 Lake Seneca Resorts WWTP
 Notice of Violation
 OPX00003; OH0076414
 Correspondence (PWW)

Lake Seneca Resorts Association
 c/o Lake Seneca Resorts Trustees
 17875 Lashley Road
 Senecaville, Ohio 43780

Dear Trustees:

We have received your self-monitoring reports covering the months of July through September 2012 for the Lake Seneca Resorts wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00610	Nitrogen, Ammonia (NH3)	7/3/2012	1D Qty	0.26	.64939
001	00610	Nitrogen, Ammonia (NH3)	7/1/2012	30D Qty	0.17	.32653
001	00665	Phosphorus, Total (P)	7/1/2012	30D Qty	0.38	1.31892
001	00530	Total Suspended Solids	7/3/2012	1D Qty	2.04	5.03405
001	00530	Total Suspended Solids	7/1/2012	30D Qty	1.37	1.5035

* 1D Conc is equal to a maximum daily concentration limit.
 1D QTY is equal to the maximum daily loading limit
 30D Conc is equal to a monthly average concentration limit.
 30D Qty is equal to the monthly average loading limit.

Your facility was also in significant noncompliance for the period of April through September 2012 for total suspended solids and ammonia nitrogen. I understand that smoke testing of the collection system was completed in November. Please submit within ten (10) days of receipt of this letter, an itemized list of all the deficiencies found in the collection system and a plan with a schedule to address the deficiencies.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

Sincerely,



Timothy A. Fulks
District Representative
Division of Surface Water

TF/dh

c: Matt Stiers