



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

November 21, 2012

Jeff Stimmel  
Stimmel Construction  
8905 Vanatta Road  
P.O. Box 737  
Logan, OH 43138

**Re: Lancaster Colony, Fairfield County  
General Storm Water Permit #4GC02786\*AG**

Dear Mr. Stimmel:

This letter is written regarding the storm water inspection that I conducted on November 19, 2012, at Lancaster Colony located at 240 West Main Street, in Lancaster, Ohio. I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed.

**Sediment and Erosion Controls:**

There was no active construction at the site. The site was mostly barren and had little erosion controls around the perimeter of the site. Please install and maintain erosion controls at the site.

Please be aware that the General Permit states that all barren areas which will remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven days. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at (614) 728-3851.

Sincerely,

  
Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

ec: Greg Sanders, CDO/DSW

GS/nsm Lancaster Colony, November 19, 2012