



John R. Kasich, Governor
Marilyn A. Mosbacher, Governor
Scott J. Smith, Director

December 12, 2012

Steve Anderson
The Daimler Group
1533 Lakeshore Drive
Columbus, Ohio 43204

**Re: Construction Storm Water Inspection at Franklin County Children Services
Permit Number: 4GC03931*AG**

Dear Mr. Anderson:

This letter is written regarding a storm water inspection I conducted at Franklin County Children Services construction site located in Whitehall, Ohio on November 29, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- Area construction is near completion. I noted the majority of the site was protected from erosion. There are small areas which remain barren. Given the time of year, temporary erosion protection measures are expected. All remaining barren areas must be protected with a crimped mulch cover or demonstrate an approvable alternative.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Steve Anderson
The Daimler Group
Page 2

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,


Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Franklin County Childrens Services 11-29-2012