



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 17, 2012

RE: HOLMES COUNTY
RTB HOLDINGS OF WALNUT CREEK
NPDES PERMIT NO. OHC000003
OHIO EPA PERMIT NO. 3GC06187
STORM WATER POLLUTION PREVENTION PLAN
REVIEW

Brian Miller
RTB Holdings of Walnut Creek
P.O. Box 206
Walnut Creek, OH 44687

Harry Matter, President
Civil Design Associates
1760 Brightwood Rd. S.E.
New Philadelphia, OH 44663

Dear Mr. Miller and Mr. Matter:

On December 3, 2012, Ohio EPA received a copy of the storm water pollution prevention plan (SWP3) for RTB Holdings of Walnut Creek, located at 2870 Cove Lane, Walnut Creek Township, Holmes County (site). After a review of the SWP3, the following deficiencies must be addressed via the submittal of a revised SWP3:

- Design details of the underground system must be included on the SWP3. The information that must be included, at a minimum, must include the following:
 - i. A profile view of the underground system that includes the base layer and appropriate elevations;
 - ii. Details regarding if the 36" pipes are perforated;
 - iii. A profile view of the underground system's outlet that includes the 1.04" diameter water quality orifice and depicts the appropriate elevations; and
 - iv. The location where the water quality orifice is to be installed.

A copy of the revised SWP3, addressing the above comments, must be submitted to my attention within ten days of receiving this correspondence. Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail at chris.moody@epa.ohio.gov.

Sincerely,

A handwritten signature in blue ink, appearing to read "Chris Moody".

Chris Moody
Environmental Specialist II
Division of Surface Water

CM/cs