



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 17, 2012

RE: TRUMBULL COUNTY
LIBERTY TOWNSHIP
BELLERIA PIZZA
5718 BELMONT AVE
NPDES GENERAL PERMIT NO. OHV000002
OHO EPA PERMIT NO. 3GV00031

Murrall, Inc.
Attn: Mike Nicholson
715 E. Midlothian Blvd.
Youngstown, OH 44502

Mr. Nicholson:

Ohio EPA performed an inspection of the wastewater treatment works serving the above-referenced facility on December 12, 2012. The inspection was performed to evaluate the operation and maintenance of the treatment works, and determine the facility's compliance with the terms and conditions of its National Pollutant Discharge Elimination System (NPDES) permit, which was issued to the property tenant, Mr. David Morgan. NPDES permits are necessary to authorize the discharge of treated wastewater to waters of the state. The current NPDES permit became effective on May 1, 2010.

This office has received confirmation from Mr. Morgan that the business has closed and vacated the building. As the property owner, you are ultimately responsible to ensure that wastewater is properly treated and disposed of at the site. It appears that the only wastewater treatment being provided at the site consists of a septic tank with an illicit discharge to a nearby storm ditch. As such, please see to it that the existing NPDES permit for the septic tank discharge is transferred to your name. Please complete and submit to this office, within 21 days' receipt of this letter, the enclosed Notice of Transfer (NOT) form.

Should you have any questions or concerns regarding this letter, please contact this office at 330-963-1120.

Respectfully,

A handwritten signature in cursive script that reads "Tomás Parry".

Tomás Parry, P.E.
Environmental Engineer
Division of Surface Water

TP/cs

Attachments: Photos
NOT form

cc: Richard Curl, R.S., Trumbull County Health Department

