



John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

November 2, 2012

Fischer Homes
570 Polaris Parkway
Suite 125
Westerville, OH 43082

RE: Alum Creek Village, Franklin County

To Whom it May Concern:

This letter is written in response to my storm water inspection on October 31, 2012, of the construction activities associated with Alum Creek Village, located along Alum Creek Drive, in Franklin County. Based on my site observations of the site and the conditions of the Storm Water Permit, the following items were noted.

Sediment and Erosion Controls:

1. There was active construction installing a sidewalk along Watkins Road. Silt fence or straw wattles need to be installed along the project area. Please see attached pictures.
2. In addition to the active construction, there were several barren sites that appeared to be near final grade. Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implemented for this site to ensure effective erosion control for the upcoming winter months.
3. Please maintain the concrete wash-out pit at the site.

Fischer Homes
Page -2

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844.

Sincerely,

A handwritten signature in black ink, appearing to read 'G L Sanders', written in a cursive style.

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

Enclosure

ec: Greg Sanders, DSW/CDO

GS/nsm Alum Creek Village, October 31, 2012

10/11/12
10/11/12
10/11/12
10/11/12
10/11/12

10/11/12
10/11/12
10/11/12
10/11/12
10/11/12

