



John Kasich, Governor
Matt D'Amico, Lt. Governor
Scott J. ... , Director

November 13, 2012

Karl Schneider
Metropolitan Partners
150 E. Broad Street
Columbus, Ohio 43215

**Re: Construction Storm Water Inspection at Lancaster Road Relocation and Phase 2, in Licking County on October 23, 2012.
Permit Numbers: 4GC03393*AG and 4GC03651*AG**

Dear Mr. Schneider:

This letter is written regarding a storm water inspection I conducted at two permitted sites in Licking County (Permit Numbers: 4GC03393*AG and 4GC03651*AG). The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- It appears the majority of the site is completed or temporally stabilized as I did not observe active construction.
- Additional temporary stabilization is required as the mandated cover is 70 percent to ensure adequate protection from erosion.

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Karl Schneider
Metropolitan Partners
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

A handwritten signature in black ink, appearing to read 'Harry Kallipolitis', with a long, sweeping horizontal stroke extending to the right.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office