



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

November 1, 2012

Clint Langley
Taco Bell of America
104 Lisa Court
McMurray, PA 15317

Re: Taco Bell – London Groveport Road / Franklin County

Dear Mr. Langley:

This letter is written regarding the storm water inspection that I conducted on October 30, 2012, at Taco Bell located along London-Groveport Road, in Grove City, Ohio. The construction appears nearly complete. I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

1. Please be aware that the General Permit mandates that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control for the upcoming winter months. Please see attached pictures.
2. Please be aware that only non-erodible fill should be placed on top of the filter fabric. Please see attached pictures.
3. After the barren areas are stabilized, you may submit a notice of termination for the site.

Post Construction Requirements:

The General Permit mandates specific water quality treatment for storm water following the completion of construction (see attachment). Please be able to demonstrate your post construction requirements per the General Permit will be met. Please submit to my attention the water quality calculations demonstrating compliance. This information can be sent to my attention via a response letter, or to my email at greg.sanders@epa.state.oh.us. The calculations should be signed and stamped by a professional engineer.

Clint Langley
Taco Bell of America
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

A handwritten signature in black ink, appearing to read 'G. Sanders', written in a cursive style.

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Gregory L. Sanders, DSW/CDO

GS/nsm Taco Bell -- London Groveport Road, October 30, 2012



