



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Wyandot County
ODOT US 30 East
NPDES Permit

December 20, 2012

Mr. Tony Lotz
ODOT District 1
2000 North West Street
Lima, Ohio 45801


Dear Mr. Lotz:

On December 12, 2012, an operation and maintenance inspection was made of the wastewater treatment plant (WWTP) serving both eastbound and westbound U.S. Route 30 rest areas. The treatment facility is located along U.S. Route 30 eastbound in Antrim Township, Wyandot County. This inspection was conducted to evaluate compliance with your facility's National Pollutant Discharge Elimination System (NPDES) permit No. 2PP00048*BD.

At the time of the inspection, the treatment facility was in operation and the contents of the aeration tanks were brown with good roll. The discharge from the plant was clear. Our review of your discharge monitoring reports (6/1/2011 to 12/1/2012) for this facility indicated one effluent violation. Please refer to the enclosed violation table.

Our completed inspection form is enclosed for your review. If you have any questions or comments, please call me at (419) 373-3021.

Yours truly,



Jason Ko
Division of Surface Water

/jlm
Enclosures
pc: Wyandot County Health Department
Neil Pry, IFM
ec: Tracking

OHIO ENVIRONMENTAL PROTECTION AGENCY
OPERATION AND MAINTENANCE INSPECTION

NPDES Permit No. 2PP00048

Facility Name: ODOT US Route 30 Expiration Date: May 31, 2014

Facility Address: US Route 30 East Date: 12/12/2012 Time: 10:30 am

City: Upper Sandusky County: Wyandot Township: Antrim

Name and Address of Owner: ODOT District 1, 2000 North West Street, Lima, OH 45801

Person Contacted: Mr. Neil Pry (Operator) Phone: (419) 748-7438

Flow: Design: 20,000 GPD Present 5000 GPD (metered)

Trib. Pop. _____ (estimated) Weather at time of inspection: Temp 32°F - Sunny

OEPA Personnel: Jason Ko District: NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None	X	Clear	X	None	X	Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: Not Observed

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has _____ excellent X good _____ fair _____ poor operation
 b. Plant has _____ excellent X good _____ fair _____ poor maintenance
 c. Sand filters have _____ excellent X good _____ fair _____ poor maintenance

d. Not operating at expected efficiency due to:

- (1) _____ hydraulic overload
 (2) _____ organic/ solids overload
 (3) _____ personnel inefficiency
 (4) _____ equipment failure
 (5) _____ wastes
 (6) _____

Disinfection: (Required May 1 thru Oct.31.)

IN OUT
 _____ Chlorination
 _____ Dechlorination
 _____ U.V

- | | | | | | | | |
|----|----------|-------|-----------------------------------|---------------------|------------------------------------|-------|-------|
| 4. | <u>X</u> | _____ | Compliance with NPDES Permit | Periodic Violations | _____ | _____ | _____ |
| 5. | <u>X</u> | _____ | Adequate Plant Safety | Chronic Violation | _____ | _____ | _____ |
| 6. | <u>X</u> | _____ | Operation and Maintenance Service | Name: | <u>Industrial Fluid Management</u> | | |

Frequency of Visits: 7/week

Facility Name: ODOT US Route 30

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	2	Trash Trap	Pumping Frequency: 1/Qtr at both rest areas.
		Grease Trap	Pumping Frequency:
	1	Bar Screen	Located in equalization basin
		Comminutor	
	2	Flow Equalization	Circulated w/ 4 mixers & 2 transfer pumps
Aeration Equipment	3	Plant Timer <u>X</u> <u>Y</u> <u> </u> <u>N</u> Motor/ Blower Unit	Cycle Time: 1 hr "ON" & ½ hr "OFF" 3 rd Blower for Post Air & Air lift pumps
Secondary Treatment	2	Aeration Tank	Color : Brown Adequate Aeration: Y <u>X</u> N <u> </u>
Final Settling	1	Clarifier	With 2 hoppers
	2	Sludge Return	In <u>X</u> Out <u> </u> Returning solids
	2	Surface Skimmer	In <u>X</u> Out <u> </u> Returning clear
	2	Fixed Media Clarifier	
Tertiary Treatment	2	Surface Sand Filter	All operational
		Polishing Pond	
		Other	
Disinfection		Chlorine	
		Dechlorination	
	OUT	Ultraviolet (UV)	
Flow Metering		Elapsed Pump Time	
	IN	Other	Water meters at both westbound/eastbound rest areas
Pumps	2	Raw Wastewater (type)	In influent pump station
	2	Sand Filter Effluent Dosing	
Sludge Handling	1	Aerated Storage Tank	Wasting 1/week about 5 mins duration
		Sludge Drying Bed	
Sludge Disposal	IN	Municipal POTW	As needed
		Landfill	
		Land Application	
Advanced Treatment	IN	Post Aeration	
		Spray Irrigation	
		Other	

Get New Data

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PP00048*BD	July 2011	001	00300	Dissolved Oxygen	1D Conc	6.0	5.41	7/28/2011