



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Crawford County  
Wagon Wheel Campground WWTP  
Ohio EPA Permit No. 2PR00187  
NPDES Permit No. OH0132551

December 11, 2012

Mr. Garry Cole  
Wagon Wheel Campground  
6787 Baker 47  
Shelby, Ohio 44875-9103

Dear Mr. Cole

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Wagon Wheel Campground wastewater treatment facility shows that this facility is in significant non-compliance (SNC) for the following parameters at outfall number 2PR00187001: Nitrogen, Ammonia. I am enclosing a list of violations for this facility for the period of May 1, 2012, through October 1, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare. When a facility is in SNC, Ohio EPA will consider escalated enforcement action

Before we initiate enforcement action, we would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within 21 days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to give us a timetable for these actions that does not extend past July 1, 2013. These actions and timetable may also be submitted by email to me at [michelle.sharp@epa.state.oh.us](mailto:michelle.sharp@epa.state.oh.us).

If you wish to meet with us to discuss this matter, please contact me at 419-373-3019 within 10 days of receiving this letter in order to set up a meeting.

Sincerely,

Michelle Sharp  
Division of Surface Water

/jlm  
Enclosure  
ec: Thomas Poffenbarger, DSW-NWDO  
Tracking

Violation Date	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value
5/1/2012	001	31616	Fecal Coliform	30D Conc	1000	13000.
5/23/2012	001	31616	Fecal Coliform	1D Conc	2000	13000.
6/1/2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.99
6/21/2012	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	1.99
7/1/2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	14.5
7/1/2012	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.06	.26728
7/13/2012	001	50060	Chlorine, Total Residu	1D Conc	0.019	.5
7/26/2012	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	14.5
7/26/2012	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.09	.26728
9/1/2012	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	3.4
9/27/2012	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	1.5	3.4