



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

December 20, 2012

RE: WAYNE COUNTY
 VILLAGE OF DOYLESTOWN
 NPDES# 3PB00014

Mayor Terry Lindeman
 Village of Doylestown
 24 South Portage Street
 Doylestown, OH 44230

Dear Mayor Lindeman:

On December 5, 2012, this writer met with Mr. Randy Danford to conduct an inspection of the sewage treatment plant for the Village of Doylestown. The intent of the inspection was to evaluate operations and maintenance of the treatment system. Additionally, the renewal process and application for the NPDES permit were discussed.

The wastewater treatment system consists of a raw influent flume, muffin monster comminutor, bar screening, two flow equalization tanks, primary clarifier/digester unit, aerated digester, trickling filter, contact aeration tank, upflow clarifier, RBC units, chlorination/dechlorination.

At the time of the inspection, the treatment system was producing a clear effluent that appeared to be of satisfactory quality. The WWTP plant was in good operation and maintenance condition.

A review of your Discharge Monitoring Reports (DMRs) covering the period June 2011 through November 2012 revealed the following effluent violations:

Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PB00014*HD	June 2011	001	Copper, Total Recovera	30D Conc	19	24.	6/1/2011
3PB00014*HD	July 2011	001	Copper, Total Recovera	30D Conc	19	25.	7/1/2011
3PB00014*HD	August 2011	001	Copper, Total Recovera	30D Conc	19	24.	8/1/2011
3PB00014*HD	September 2011	001	Copper, Total Recovera	30D Conc	19	23.	9/1/2011
3PB00014*HD	December 2011	581	Nitrogen Kjeldahl, Tot	1D Conc	75	13800.	12/1/2011
3PB00014*HD	February 2012	001	Mercury, Total (Low Le	30D Conc	12	20.	2/1/2012
3PB00014*HD	April 2012	001	Mercury, Total (Low Le	30D Conc	12	20.	4/1/2012
3PB00014*HD	July 2012	001	Mercury, Total (Low Le	30D Conc	12	20.	7/1/2012
3PB00014*HD	August 2012	001	Mercury, Total (Low Le	30D Conc	12	102.	8/1/2012
3PB00014*HD	September 2012	001	Copper, Total Recovera	30D Conc	19	40.	9/1/2012
3PB00014*HD	September 2012	001	Mercury, Total (Low Le	30D Conc	12	143.	9/1/2012
3PB00014*HD	September 2012	001	Copper, Total Recovera	1D Conc	30	40.	9/12/2012
3PB00014*HD	October 2012	001	Mercury, Total (Low Le	30D Conc	12	107.	10/1/2012

VILLAGE OF DOYLESTOWN
DECEMBER 20, 2012
PAGE 2 OF 2

Overall, the results of this inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/cs

cc: Wayne County Health Dept.
Randy Danford, Public Utility Manager, Village of Doylestown

File: Public/Doylestown/PC