



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Richland County
PGW, LLC
NPDES Permit

December 28, 2012

Mr. Nick Matthews, EHS Manager
Pittsburgh Glass Works, LLC
5066 Lincoln Highway
Crestline, Ohio 44827

Dear Mr. Matthews:

On November 16, 2012, an inspection was made of the industrial storm water discharges originating from the PGW glass manufacturing facility located at 5066 Lincoln Highway, Crestline, Richland County. Mr. Jamie Schnuth of Veolia Water and you were present to provide a tour and answer questions. The inspection included a tour of industrial process wastewater and sanitary waste treatment systems.

The inspection did not reveal any concerns over the operations of the industrial and sanitary treatment plants. All major pieces of equipment were in working order and functioning properly.

During the inspection, you mentioned that the deficiencies identified during our previous storm water inspection had been corrected. The trash bin outside of door W202 has been removed. The outside storage bins in the forklift maintenance area have been moved inside the building and old equipment that had accumulated in this area has been moved off site for scrap.

A review of your discharge monitoring reports submitted to our office for the months of May through November 2012 revealed one violation of the limits contained in your National Pollutant Discharge Elimination System (NPDES) permit. This violation was for exceeding the Oil and Grease limit at the 001 outfall. Violations of your permit may lead to enforcement action and steps should be taken to prevent future violations.

Please contact me at 419-373-3070 if you have any questions.

Sincerely,

Walter Ariss, P.E.
Environmental Specialist II
Division of Surface Water

/jlm
Enclosure
ec: Tracking



State of Ohio Environmental Protection Agency
Northwest District Office


NPDES Compliance Inspection Report
Semi-Public Sewage Disposal Inspection Form

Section A: National Data System Coding

Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
2EI00004	OH0000540	11/16/12	C	S	1

Section B: Facility Data

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
PGW Crestline 5066 Lincoln Highway Crestline OH 44827	10:00 AM	January 1, 2008
	Exit Time	Permit Expiration Date
	11:00 PM	December 31, 2012
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Nick Matthews EHS Manager	419-526-7412	

Ohio EPA Inspector	Ohio EPA Reviewer
 Date: 12/28/12	
Walter Ariss, P.E. Environmental Specialist II Division of Surface Water Northwest District Office	Thomas Poffenbarger, P.E. Water Quality Engineer II / Unit Supervisor Division of Surface Water