



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: **Notice of Violation**  
Ottawa County  
Fenwick Marina  
Ohio EPA Permit No.2PR00130\*CD

January 3, 2013

Ms. Cathy Gradel, Owner  
Fenwick Marina  
10195 West State Route 2  
Oak Harbor, Ohio 43449

Dear Ms. Gradel:

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Fenwick Marina wastewater treatment plant (WWTP) shows that this facility is in significant non-compliance (SNC) for Chlorine, Total Residual at final outfall number 001. I am enclosing a list of violations for this facility for the period of January 1, 2012, through November 30, 2012.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

Before we initiate enforcement action, we would like to work with you to achieve satisfactory progress to bring this facility back into compliance. Within 21 days of the date of this letter, please submit, in writing, the actions that you propose to undertake in order to return your facility into compliance with your NPDES permit. You will also need to provide us a timetable to implement these actions within a reasonable timeframe. These actions and timetable may also be submitted by email to me at [rick.zuzik@epa.ohio.gov](mailto:rick.zuzik@epa.ohio.gov).

If you wish to meet with us to discuss this matter, please contact me at 419-373-3020 within 10 days of receiving this letter in order to set up a meeting.

Sincerely,

Richard A. Zuzik, MSE  
Division of Surface Water

/jlm  
Enclosure  
ec: Tracking

Get New Data								
Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PR00130*CD	May 2012	001	50060	Chlorine, Total Residu	1D Conc	0.038	.07	5/16/2012
2PR00130*CD	June 2012	001	31648	E. coli	30D Conc	161	460	6/1/2012
2PR00130*CD	June 2012	001	31648	E. coli	7D Conc	362	460	6/15/2012
2PR00130*CD	June 2012	001	50060	Chlorine, Total Residu	1D Conc	0.038	.05	6/18/2012
2PR00130*CD	July 2012	001	50060	Chlorine, Total Residu	1D Conc	0.038	.07	7/9/2012
2PR00130*CD	August 2012	001	50060	Chlorine, Total Residu	1D Conc	0.038	.05	8/13/2012
2PR00130*CD	August 2012	001	00300	Dissolved Oxygen	1D Conc	6.0	5.1	8/13/2012
2PR00130*CD	September 2012	001	50060	Chlorine, Total Residu	1D Conc	0.038	.08	9/17/2012
2PR00130*CD	September 2012	001	00300	Dissolved Oxygen	1D Conc	6.0	4.2	9/17/2012
2PR00130*CD	October 2012	001	50060	Chlorine, Total Residu	1D Conc	0.038	.11	10/1/2012
2PR00130*CD	October 2012	001	00300	Dissolved Oxygen	1D Conc	6.0	3.9	10/1/2012