



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 2, 2013

Mayor and Council
Village of Higginsport
P.O. Box 121
Higginsport, OH 45131

**RE: Higginsport WWTP – 1PA00028*CD
Notice of Violation**

Dear Permittee:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on December 20, 2012. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions. Future violations must be reported as required by the NPDES permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

ec: Higginsport@Frontier.com



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

Notice of Violation Report

Facility: Higginsport WWTP

Permit No.: 1PA00028*CD

Report Period: November 2012

Date Received: 12/20/2012

Code	Type	Effective Date	Parameter ID	Parameter Name	Frequency	Limit	Value
001	Limit	11/1/2012	00610	Nitrogen, Ammonia (NH3)	Monthly Conc.	3.0	9.915
001	Limit	11/15/2012	00610	Nitrogen, Ammonia (NH3)	Weekly Conc.	4.5	18.