



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

January 9, 2013

Re: Athens County
 Village of Albany
 Notice of Violation
 NPDES Permit 0PB00087*BD
 Correspondence (PWW)

Mayor and Council
 Village of Albany
 5153 Alton Street
 Albany, Ohio 45710

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
January 2012:					
001	Total Suspended Solids	30D Conc	12	68.175	1/1/2012
001	Total Suspended Solids	30D Qty	5.9	47.2689	1/1/2012
001	CBOD 5 day	30D Conc	10	15.1	1/1/2012
001	CBOD 5 day	30D Qty	4.9	10.7875	1/1/2012
001	Dissolved Oxygen	1D Conc	6.0	5.1	1/2/2012
001	Total Suspended Solids	7D Conc	18	253.5	1/15/2012
001	Total Suspended Solids	7D Qty	8.9	182.978	1/15/2012
001	CBOD 5 day	7D Conc	15	57.7	1/15/2012
001	CBOD 5 day	7D Qty	7.4	42.2201	1/15/2012
001	Dissolved Oxygen	1D Conc	6.0	5.6	1/23/2012
001	Dissolved Oxygen	1D Conc	6.0	5.8	1/24/2012
001	Dissolved Oxygen	1D Conc	6.0	5.5	1/25/2012
001	Dissolved Oxygen	1D Conc	6.0	5.8	1/26/2012
February 2012:					
001	Total Suspended Solids	30D Conc	12	17.2444	2/1/2012
001	Total Suspended Solids	7D Conc	18	51.4	2/1/2012
001	Total Suspended Solids	30D Qty	5.9	6.52955	2/1/2012
001	Total Suspended Solids	7D Qty	8.9	18.1948	2/1/2012
001	Nitrogen, Ammonia (NH3)	30D Conc	3	3.08667	2/1/2012
001	Nitrogen, Ammonia (NH3)	7D Conc	4.5	13.625	2/1/2012
001	Nitrogen, Ammonia (NH3)	7D Qty	2.2	4.84527	2/1/2012

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	CBOD 5 day	7D Conc	15	25.	2/1/2012
001	CBOD 5 day	7D Qty	7.4	8.89475	2/1/2012
March 2012:					
001	Total Suspended Solids	7D Conc	18	21.5	3/22/2012
April 2012:					
001	Nitrogen, Ammonia (NH3)	7D Conc	4.5	6.715	4/1/2012
May 2012:					
001	Total Suspended Solids	30D Conc	12	12.1	5/1/2012
001	Total Suspended Solids	30D Qty	5.9	6.73919	5/1/2012
001	Fecal Coliform	7D Conc	2000	7000.	5/1/2012
001	CBOD 5 day	30D Qty	4.9	5.31757	5/1/2012
001	Total Suspended Solids	7D Conc	18	30.5	5/8/2012
001	Total Suspended Solids	7D Qty	8.9	21.4420	5/8/2012
001	CBOD 5 day	7D Conc	15	20.55	5/8/2012
001	CBOD 5 day	7D Qty	7.4	14.6555	5/8/2012
001	CBOD 5 day	7D Conc	15	20.8	5/15/2012
001	CBOD 5 day	7D Qty	7.4	9.64418	5/15/2012
June 2012:					
001	Total Suspended Solids	30D Conc	12	13.375	6/1/2012
001	Oil and Grease, Total	1D Conc	10	18.5	6/6/2012
001	Total Suspended Solids	7D Conc	18	28.	6/8/2012
001	Total Suspended Solids	7D Qty	8.9	10.0983	6/8/2012
July 2012:					
001	Fecal Coliform	7D Conc	2000	5200.	7/1/2012
001	Dissolved Oxygen	1D Conc	6.0	5.9	7/3/2012
October 2012:					
001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	1.615	10/8/2012

Notes: 1D Conc = Daily Average Concentration Value
1D Qty = Daily Average Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Also, you are reminded that you are required to report any non-compliance that is the result of any violation of a daily maximum discharge limit or due to an upset or unanticipated bypass that results in an exceedance of any effluent limitation within 24 hours of discovery by email or telephone, with a written follow-up notice within 5 days. Report all other instances of NPDES permit non-compliance on your Discharge Monitoring Report.

Please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5416.

Sincerely,

A handwritten signature in black ink that reads "Nicholas G. Hammer". The signature is written in a cursive style with a large initial "N" and "H".

Nicholas G. Hammer
Environmental Specialist II
Permits and Enforcement Section
Division of Surface Water

NH/dh

c: Thomas Burnett, Operator of Record