



John R. Kasich, Governor  
 Mary Taylor, Lt. Governor  
 Scott J. Nally, Director

January 9, 2013

**Re:** Athens County  
 Arcadia Nursing Center, Inc.  
 Notice of Violation  
 Ohio EPA Permit 0PR00096\*DD  
 Correspondence (PWW)

Facility Manager  
 Arcadia Care Center  
 25675 Main Street  
 Coolville, Ohio 45723

To Whom It May Concern:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Outfall	Parameter	Type*	Limit	Reported Value	Violation Date
January 2012	001	Nitrogen, Ammonia (NH3)	30D Conc	5.0	5.5	1/1/2012
July 2012	001	Nitrogen, Ammonia (NH3)	30D Conc	1.5	5.6	7/1/2012
July 2012	001	Nitrogen, Ammonia (NH3)	30D Qty	0.0614	.16109	7/1/2012
July 2012	001	Nitrogen, Ammonia (NH3)	1D Conc	2.3	5.6	7/31/2012
July 2012	001	Nitrogen, Ammonia (NH3)	1D Qty	0.0941	.16109	7/31/2012
August 2012	001	pH	1D Conc	6.5	6.1	8/3/2012
August 2012	001	pH	1D Conc	6.5	6.	8/10/2012
November 2012	001	Total Suspended Solids	30D Conc	12	30.	11/1/2012
November 2012	001	Total Suspended Solids	30D Qty	0.491	.59341	11/1/2012
November 2012	001	CBOD 5 day	30D Conc	10	17.	11/1/2012
November 2012	001	Total Suspended Solids	1D Conc	18	30.	11/29/2012
November 2012	001	CBOD 5 day	1D Conc	15	17.	11/29/2012


**\*NOTES:** 1D Conc = Daily Average Concentration Value  
 1D Qty = Daily Average Loading Value  
 7D Conc = Weekly Average Concentration Value  
 30D Conc = Monthly Average Concentration Value  
 7D Qty = Weekly Average Loading Value  
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5416 or [nick.hammer@epa.ohio.gov](mailto:nick.hammer@epa.ohio.gov).

Sincerely,



Nicholas G. Hammer  
Environmental Specialist  
Permits and Enforcement Section  
Division of Surface Water

NH/dh

- c: Mike Wisecarver, Wisecarver Environmental, Inc.
- c: Paul Love, Operator of Record