



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

January 9, 2013

Re: Athens County
 Hockingport Mobile Home Park
 Notice of Violation
 Ohio EPA Permit 0PV00014*DD
 Correspondence (PWW)

Mr. Roger Ketchum
 Hockingport Mobile Home Park
 P.O. Box 551
 Hockingport, Ohio 45739

Dear Mr. Ketchum:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Outfall	Parameter	Type*	Limit	Reported Value	Violation Date
July 2012	001	Nitrogen, Ammonia (NH3)	30D Conc	1.0	2.74	7/1/2012
July 2012	001	Dissolved Oxygen	1D Conc	6.0	5.17	7/9/2012
July 2012	001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	2.74	7/22/2012

Reporting Period	Outfall	Parameter	Type	Limit	Reported Value	Violation Date
July 2012	001	Nitrogen, Ammonia (NH3)			AJ	7/12/2012
July 2012	001	Nitrogen, Ammonia (NH3)			AJ	7/12/2012
July 2012	001	Nitrogen, Ammonia (NH3)			AJ	7/12/2012
July 2012	001	Nitrogen, Ammonia (NH3)			AJ	7/12/2012

***NOTES:** 1D Conc = Daily Average Concentration Value
 1D Qty = Daily Average Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5416 or nick.hammer@epa.ohio.gov.

Sincerely,

A handwritten signature in cursive script that reads "Nicholas G. Hammer".

Nicholas G. Hammer
Environmental Specialist
Permits and Enforcement Section
Division of Surface Water

NH/dh