



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

July 10, 2012

Mr. Eric Siefring, Owner
A and E Campground
2062 North Star-Fort Loramie Road
New Weston, Ohio 45348

**RE: A and E Campground Reconnaissance Inspection
NPDES Permit No. 1PR00101*CD / OH0127108**

Dear Mr. Siefring:

I am writing in follow-up to my June 28, 2012, Reconnaissance Inspection at A and E Campground, 3299 State Route 540, Jefferson Township, Logan County. The inspection was performed as part of the camp's compliance review.

The inspection findings are included in the enclosed report. There is one item that requires a written response. Please provide the requested information no later than the date noted.

If you have any questions, please call me at (937) 285-6097.

Sincerely,

Joseph Reynolds
Environmental Specialist
Division of Surface Water

JR/tf

Enclosure

cc: Logan County Health Department

Inspection Findings

On June 28, 2012, I conducted a reconnaissance inspection at A & E Campgrounds (3299 State Route 540). Brent Luttmmer (Office Manager) was present for the inspection. The owner Eric Siefring was out of town.

The wastewater treatment system consists of a trash trap, flow equalization tank, extended aeration tank, clarification, (2) slow surface sand filters, chlorination/dechlorination post aeration tank.

The campground waste system only discharges during certain times of the year (low flow due to recent start-up). The flow equalization tank was empty. The aeration tank had uniform mixing. The mixed liquor was light brown. The clarifier was not discharging as the water level was 1" below the weir. Pin floc solids were noted in the tank. Both tertiary sand filters were dry. A few weeds were noted on their surface. The chlorine contact tank was clear (no discharge). The post aeration was working. There was no discharge from the system.

Between August 2011 and April, 2012 the camp reported one ammonia violation. In addition to the ammonia violation, there were the following frequency violations: flow (1), color (13), odor (13) and turbidity (14).

The wastewater treatment system should be placed under the responsible charge of a Class A operator. System monitoring in accordance with the facility NPDES permit will need to be performed. During months when there is no discharge the Electronic Discharge Monitoring Reports (EDMR's) should be checked for no discharge.

Item Requiring a Response

1. An Operator of Record form must be completed and return to Ohio EPA by the operator who will be placed in responsible charge of plant operations. This form must be submitted as soon as possible (no later than August 17, 2012).



State of Ohio Environmental Protection Agency
Southwest District Office

NPDES Compliance Inspection Report



Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
1PR00101*CD	OH0127108	6/28/2012	R	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
A and E Campground 3299 State Route 540 Bellefontaine, Ohio	11:00 AM	9/1/2010
	Exit Time	Permit Expiration Date
	11:30 AM	8/31/2015
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Brent Luttmmer, Office Manager	(937) 593 - 0220	
Name, Address and Title of Responsible Official	Phone Number	
Eric Siefiring, Owner 2062 North Star Fort Loramie Road New Weston, Ohio 45348	(937) 593 - 0220	

Section C: Areas Evaluated During Inspection					
(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)					
S	Permit	N	Flow Measurement	N	Pretreatment
S	Records/Reports	N	Laboratory	N	Compliance Schedule
M	Operations & Maintenance	N	Effluent/Receiving Waters	N	Self-Monitoring Program
N	Facility Site Review	N	Sludge Storage/Disposal	N	Other
N	Collection System				

Section D: Summary of Findings (Attach additional sheets if necessary)

See attached report.

Inspector	Reviewer
 Joe Reynolds Division of Surface Water Southwest District Office Date: 7/10/12	 Martyn Burt Compliance & Enforcement Supervisor Division of Surface Water Southwest District Office Date: 7/10/12