



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

January 9, 2013

Re: Washington County
 Hervida 4-H Camp, Inc.
 Self-Monitoring Report Violations
 Ohio EPA Permit 0PR00107*DD
 NPDES Permit OH0114898
 Correspondence (PWW)

Mr. Don Eifler, Camp Manager
 Hervida 4-H Camp, Inc.
 220 Davis Avenue
 Marietta, Ohio 45750

Dear Mr. Eifler:

We have received your self-monitoring reports covering the months of July through September 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	Total Suspended Solids	30D Conc	12	25.	7/1/2012
001	Total Suspended Solids	1D Conc	18	25.	7/24/2012
001	Total Suspended Solids	30D Conc	12	28.	8/1/2012
001	Total Suspended Solids	1D Conc	18	28.	8/10/2012
001	Chlorine, Total Residual	1D Conc	0.038	.2	8/12/2012
001	Chlorine, Total Residual	1D Conc	0.038	.8	8/17/2012
001	Chlorine, Total Residual	1D Conc	0.038	.2	8/20/2012
001	Chlorine, Total Residual	1D Conc	0.038	.7	8/24/2012
001	Total Suspended Solids	30D Conc	12	16.	9/1/2012
001	E. coli	30D Conc	161	450.	9/1/2012
001	Chlorine, Total Residual	1D Conc	0.038	1.3	9/6/2012
001	Chlorine, Total Residual	1D Conc	0.038	1.	9/7/2012
001	Chlorine, Total Residual	1D Conc	0.038	5.	9/13/2012
001	E. coli	1D Conc	362	450.	9/14/2012
001	Chlorine, Total Residual	1D Conc	0.038	5.3	9/14/2012
001	Chlorine, Total Residual	1D Conc	0.038	.4	9/18/2012
001	Chlorine, Total Residual	1D Conc	0.038	.6	9/20/2012
001	Chlorine, Total Residual	1D Conc	0.038	.7	9/23/2012
001	Chlorine, Total Residual	1D Conc	0.038	.4	9/28/2012

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. For more information about pollution prevention, including fact sheets or U.S. EPA's "*Facility Pollution Prevention Guide*" (EPA/600/R-92.008), please contact the Ohio EPA Pollution Prevention Section at (614) 644-3469.

If there are any questions, please contact me at (740) 380-5434.

Sincerely,

A handwritten signature in black ink, appearing to read "Stephen Wells", written in a cursive style.

Stephen Wells
District Representative
Division of Surface Water

SW/dh