



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Mally, Director

December 19, 2012

Michael Hooper
City of Westerville-Parks and Recreation
350 North Cleveland Avenue
Westerville, OH 43082

**Re: Storm Water Inspection at Highland Park / Franklin County
Permit #4GC03880*AG**

Dear Mr. Hooper,

This letter is written regarding the storm water inspection I conducted by at Highland Park in Westerville, Ohio on December 11, 2012. The Agency understands these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls

- The site was seeded and germination is becoming established. The application of a crimped straw mulch cover as previously requested is not expected at this time. The site will be re-evaluated for termination next growing season. Successful vegetation is measures by a minimum density of 70 percent
- The temporary riser associated with the sediment impoundment may be removed.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office
HK/nsm Highland Park 12-11-2012