



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 9, 2013

**RE: SHAWNEE LOOKOUT WWTP
NPDES PERMIT 1PG00084*DD, OH0023752
NOTICE OF VIOLATION**

Mr. Tom Prues
Hamilton County Park District
10245 Winton Road
Cincinnati, Ohio 45231

Dear Mr. Prues:

I have conducted a compliance review of the Discharge Monitoring Reports (DMR) for the months of June 2012 through November 2012 for the referenced facility's NPDES permit. My review indicates violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 1PG00084001

<u>Parameter</u>	<u>Date</u>	<u>Permit Limit</u>	<u>Value Reported</u>
Nitrogen, Ammonia	6/1/2012	1.0 mg/l	1.4 mg/l
Nitrogen, Ammonia	9/1/2012	1.0 mg/l	1.2 mg/l
Nitrogen, Ammonia	10/1/2012	1.0 mg/l	1.1 mg/l

Non-compliance notifications were sent to this agency regarding each of the violations above from the Operator of Record for this facility, Dan Wuebbler. We also met to discuss the significant non-compliance status of this facility on September 13, 2012, and have received your plan of action to return to compliance in a letter dated November 30, 2012, from Kevin Brill of the Hamilton County Park District. No further response to this Notice of Violation is necessary.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

Mary Osika
Environmental Specialist
Division of Surface Water

ec: Harry Perry, Hamilton County Park District
Dan Wuebbler, EWS

MO\bp