



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 10, 2013

RE: MAHONING COUNTY
PRECISION (OHIO), LLC
NPDES PERMIT NO. OHR000005
OHIO EPA PERMIT NO. 3GR01107*EG
INDUSTRIAL STORM WATER INSPECTION

Ronald Larson
Precision (Ohio), LLC
3850 Hendricks Road
Austintown, OH 44515

Dear Mr. Larson:

On December 5, 2012, Ohio EPA conducted an inspection at Precision (Ohio), LLC, located at 3850 Hendricks Road, Austintown Township, Mahoning County (facility). During the inspection, the facility was represented by Michael Patton, Plant Manager Ohio Operations.

The facility's industrial activities are categorized by Standard Industrial Classification (SIC) Code 3999: Manufacturing Industries, Not Elsewhere Classified and are authorized by General National Pollutant Discharge Elimination System Permit for Storm Water Associated with Industrial Activity (Multi-Sector General Permit), permit No. 3GR01107*EG.

Site Inspection

The inspection documented the following:

- The facility's storm water pollution prevention plan (SWP3) was last updated in September 2007 and is not reflective of the requirements established within the Multi-Sector General Permit. The SWP3 must be revised to be reflective of the requirements of the Multi-Sector General Permit.
- Floor drains are located within the facility. Mr. Patton did not know if the floor drains were connected to the storm sewer system or sanitary sewer system. The facility is currently in the engineering phase for a new fifteen-ton crane. According to the engineering drawings, the floor drains are connected to the sanitary sewer system.
- Storm water inspections are being performed on a weekly frequency. Ohio EPA requested that the inspection report be modified to include the oil storage and spill kit locations.
- A preventative maintenance has been established for equipment utilized at the facility.
- An annual comprehensive site inspection was performed April 19, 2012.


PRECISION (OHIO), LLC
JANUARY 11, 2013
PAGE 2 OF 2

Corrective Action

The facility's SWP3 must be revised within thirty days to address the requirements of the Multi-Sector General Permit and the industrial activities being performed at the facility.

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via email chris.moody@epa.ohio.gov.

Sincerely,



Chris Moody
Environmental Specialist II
Division of Surface Water

CM/cs

Cc: Michael Patton, Plant Manager Ohio Operations, Precision LLC