



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

January 24, 2013

RE: SUMMIT COUNTY
 COPLEY TOWNSHIP
 COPLEY TOWNE CENTRE
 2830 COPLEY ROAD
 COMPLIANCE EVALUATION INSPECTION
 OHIO EPA PERMIT #3PR00381*CD

Mr. John Poleondakis
 Levendi Enterprises
 2830 Copley Road
 Akron, OH 44321

Dear Mr. Poleondakis:

On January 18, 2013, a Compliance Evaluation Inspection (CEI) was conducted at the above referenced wastewater treatment plant (WWTP). The existing wastewater treatment system consists of a discharging extended aeration tank with clarifier.

During the recent inspection, the plant was running. The mixed liquor in the aeration tank was not the appropriate chocolate brown color. Rather, it was light in color with lots of white foam.

Upon reviewing our files, it was noted that you continue to be in non-compliance with your National Pollutant Discharge Elimination System (NPDES) permit's compliance schedule. According to your compliance schedule, an appropriately sized dosing chamber with elapsed time meters, surface sand filters, and chlorination/dechlorination tank were to be constructed by February 1, 2012. A Permit-to-Install (PTI) for the upgrade was issued by the Director of Ohio EPA on July 19, 2011. Construction of the upgrade must begin within 18 months from the effective date of that PTI. Otherwise, the PTI will expire.

Review of the electronic Discharge Monitoring Reports (eDMRs) submitted for your plant from January 2012 through December 2012 revealed the following effluent violations:

Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2012	Total Suspended Solids	30D Conc	12	63.	3/1/2012
March 2012	Total Suspended Solids	7D Conc	18	63.	3/1/2012
March 2012	Nitrogen, Ammonia (NH3)	30D Conc	3.0	13.3	3/1/2012
March 2012	Nitrogen, Ammonia (NH3)	7D Conc	4.5	13.3	3/1/2012
March 2012	CBOD 5 day	30D Conc	10	42.2	3/1/2012
March 2012	CBOD 5 day	7D Conc	15	42.2	3/1/2012
June 2012	E. coli	30D Conc	161	1400.	6/1/2012
June 2012	E. coli	7D Conc	362	1400.	6/1/2012
August 2012	E. coli	30D Conc	161	7100.	8/1/2012
August 2012	E. coli	7D Conc	362	7100.	8/1/2012

COPLEY TOWNE CENTRE
JANUARY 24, 2013
PAGE 2 OF 2

Please be advised that the above mentioned instances of noncompliance are subject to enforcement pursuant to Ohio Revised Code (ORC) 6111.

It is understood that the Copley Township Board of Trustees is working with the City of Akron to obtain sanitary sewers in the Copley-Jacoby Roads area. This office has not received any written update from the City of Akron pertaining to commencement of construction of said sewers.

Please understand that you are legally bound by your NPDES permit to meet the dates in your permit's Compliance Schedule, thereby, making it possible for you to meet the tertiary effluent limitations in your permit. Until the WWTP is properly upgraded, this office cannot give a favorable recommendation to any new tenants utilizing the treatment plant. Furthermore, this office has no choice but to refer this situation to our legal department to initiate escalated enforcement actions. As soon as possible, please notify this office in writing of your intentions to obtain compliance. If you have any questions, contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/cc

cc: Matt Springer, Copley Twp. Zoning Dept.
Pat Gsellman, City of Akron, Akron Engineering Bureau
Helen Humphrys, President, Copley Township Board of Trustees

ec: Tom LaPlante, Summit County Health Dept.