



Edith L. Keefe, Governor
Richard Taylor, Lt. Governor
Susan M. Kelly, Director

January 24, 2013

Ryan Homes
921 Eastwind Drive
Suite 118
Westerville, OH 43081

**Re: Woodstream, Sec. 4, Ph. 1 / Fairfield County
Construction Storm Water General Permit #4GC03390**

Dear Sir or Madam:

This letter is written regarding the storm water inspection I conducted on January 17, 2013, of the construction activities at Woodstream, Sec. 4, Ph. 1, located near the intersection of Hill Road and Busey Road,. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

The project site had several active home sites under construction. Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated. Given the time of year alternate erosion control measures such as erosion control matting, crimped mulching, mulch with netting and/or tackifier, or an approvable alternative must be implement for this site to ensure effective erosion control during the winter months. Please see attached pictures.

A few small sections of straw waddles were installed. However most of the straw waddles were in need of repair or additional new waddles needed to be installed. Please see attached pictures.

The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Steve Peck
Dominion Homes
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

A handwritten signature in black ink, appearing to read 'GLS', written in a cursive style.

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

Enclosure

ec: Greg Sanders, DSW/CDO

GLS/nsm Woodstream, Sec. 4, Ph. 1, January 17, 2013

