



John R. Kasich, Governor  
 Mary Taylor, Lt. Governor  
 Scott J. Nally, Director

January 30, 2013

**Re:** Athens County  
 Village of Chauncey  
 Notice of Violation  
 NPDES Permit OPB00006\*HD  
 Correspondence (PWW)

Mayor and Council  
 Village of Chauncey  
 42 Converse Street  
 Chauncey, Ohio 45719

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Outfall	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2012	001	E. coli	7D Conc	284	727.348	5/15/2012
July 2012	001	Dissolved Oxygen	1D Conc	5.0	3.8	7/3/2012
October 2012	001	E. coli	7D Conc	284	489.892	10/22/2012

**Frequency Violation:**

Reporting Period	Outfall	Parameter	Sample Frequency	Expected	Reported	Violation Date
June 2012	001	Mercury, Total (Low Level)	2/Year	1	0	6/1/2012

**Notes:** 1D Conc = Daily Average Concentration Value  
 1D Qty = Daily Average Loading Value  
 7D Conc = Weekly Average Concentration Value  
 30D Conc = Monthly Average Concentration Value  
 7D Qty = Weekly Average Loading Value  
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your reports addressing the reasons for the May and October E. coli violations. No additional information is requested at this time for these violations. Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the remaining two referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions, please contact me at (740) 380-5416 or [nick.hammer@epa.ohio.gov](mailto:nick.hammer@epa.ohio.gov).

Sincerely,



Nicholas G. Hammer  
Environmental Specialist  
Division of Surface Water

NH/dh

c: Joe Riley, Operator of Record