



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

February 1, 2013

Re: Belmont County
 Village of Shadyside WWTP
 Notice of Violation
 NPDES Permit OPC00009*FD
 Correspondence (PWW)

Board of Public Affairs
 Village of Shadyside
 50 East 39th Street
 Shadyside, Ohio 43947

Dear Board Members:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance and/or deficiency is listed below:

Reporting Period	Outfall	Parameter	Limit Type*	Limit	Reported Value	Violation Date
July 2012	001	Fecal Coliform	7D Conc	400	1363.15	7/15/2012

*1D Conc = Daily Maximum Concentration Value
 1D Qty = Daily Maximum Loading Value
 7D Conc = Weekly Average Concentration Value
 30D Conc = Monthly Average Concentration Value
 7D Qty = Weekly Average Loading Value
 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violation, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5416 or nick.hammer@epa.ohio.gov.

Sincerely,



Nicholas G. Hammer
Environmental Specialist
Division of Surface Water

NH/dh

c: Doug Beekman, Superintendent, Shadyside WWTP