



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Richland County
Mohican State Forest WWTP
NPDES Permit

January 30, 2013

Mr. Chad Sanders
Mohican State Forest WWTP
945 ODNR Mohican 60
Perrysville, Ohio 44864

Dear Mr. Sanders:

On January 4, 2013, an inspection was made of the wastewater treatment facilities serving the former Mohican Juvenile Correction Facility located at 1012 ODNR Mohican 51, Perrysville, Ashland County. Mr. Kevin Dean, your contract certified operator, was present during the inspection to provide a tour of the facilities and answer any questions. The inspection was completed as part of the renewal process for the facility's National Pollutant Discharge Elimination System (NPDES) discharge permit #2PP00005.

The facility has been vacant since the Department of Youth Services moved out in 2010. The only sanitary wastewater generated is by staff who visits the buildings to maintain security and perform grounds maintenance. The older train of the treatment plant has been pumped out and has been partially filled with clean water to prevent the tanks from "popping". The newer train is utilized to treat any wastewater that is generated. The blowers and pumps are operated once/week to maintain treatment. They are turned off the remainder of the week.

A review of the discharge monitoring reports submitted for the months of January 2010 through December 2012 revealed two **violations** of the limits contained in your NPDES permit. Both violations were for exceeding the total suspended solids limit in the March 2011 and May 2012 sample.

Our office has begun drafting your renewal NPDES permit and you will receive a draft copy before the permit is issued final. Please look this draft copy over and contact our office with any questions or concerns you might have.

Please call me at 419-373-3070 if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Walter Ariss".

Walter Ariss, P.E.
Environmental Specialist II
Division of Surface Water

/jlm
Enclosure
pc: Kevin Dean, Dean's Backflow Service
ODNR, Division of Forestry
ec: Tracking



State of Ohio Environmental Protection Agency
Northwest District Office

NPDES Compliance Inspection Report
Semi-Public Sewage Disposal Inspection Form

Section A: National Data System Coding					
Permit #	NPDES#	Month/Day/Year	Inspection Type	Inspector	Facility Type
2PP00005	OH0052558	01/04/13	C	S	1

Section B: Facility Data		
Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Mohican State Forest WWTP 1012 ODNR Mohican 51 Perrysville OH 44864	10:00 AM	January 1, 2008
	Exit Time	Permit Expiration Date
	11:00 AM	February 28, 2013
Name(s) and Title(s) of On-Site Representatives	Phone Number(s)	
Kevin Dean, Certified Operator		

Ohio EPA Inspector	Ohio EPA Reviewer
 Walter Ariss, P.E. Environmental Specialist II Division of Surface Water Northwest District Office	
<i>1/4/13</i> Date	