



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

February 4, 2013

Re: Belmont County
 Barnesville WWTP
 Self-monitoring Report Violations
 Ohio EPA Permit OPC00001*HD
 Correspondence (PWW/Major)

Mayor and Council
 Village of Barnesville
 132 N. Arch Street
 Barnesville, Ohio 43713

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Outfall	Parameter	Limit Type*	Limit	Reported Value	Violation Date
October 2012	001	Fecal Coliform	7D Conc	2000	2262.74	10/8/2012

Reporting Period	Outfall	Parameter	Reported Value	Violation Date
May 2012	001	Fecal Coliform	AK	5/23/2012
Sept. 2012	801	Fecal Coliform	AK	9/5/2012
Sept. 2012	001	Fecal Coliform	AK	9/26/2012

- * 1D Conc = Daily Average Concentration Value
- 1D Qty = Daily Average Loading Value
- 7D Conc = Weekly Average Concentration Value
- 30D Conc = Monthly Average Concentration Value
- 7D Qty = Weekly Average Loading Value
- 30D Qty = Monthly Average Loading Value
- AK = Biological Sample too Numerous to Count

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5416 or nick.hammer@epa.ohio.gov.

Sincerely,



Nicholas G. Hammer
Environmental Specialist
Division of Surface Water

NH/dh

Enclosures

c: Roger Deal, Village Admin., Village of Barnesville
c: Gary Billman, Plant Supt., Village of Barnesville WWTP