



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

February 1, 2013

Re: Belmont County
 EORWA
 Self-monitoring Report Violations
 Ohio EPA Permit OPQ00000*ND
 Correspondence (PWW/Major)

Board of Trustees
 Eastern Ohio Regional Wastewater Authority
 P.O. Box 508
 Bridgeport, Ohio 43912

Dear Board Members:

We have received your self-monitoring reports covering the months of January through November 2012 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Outfall	Parameter	Limit Type*	Limit	Reported Value	Violation Date
May 2012	001	Total Suspended Solids	7D Conc	45	46.9	5/1/2012
May 2012	001	Total Suspended Solids	7D Qty	852	859.929	5/1/2012

Frequency Violation:

Reporting Period	Outfall	Parameter	Sample Frequency	Expected	Reported	Violation Date
July 2012	001	Fecal Coliform	3/Week	3	2	7/1/2012

- * 1D Conc = Daily Maximum Concentration Value
- 1D Qty = Daily Maximum Loading Value
- 7D Conc = Weekly Average Concentration Value
- 30D Conc = Monthly Average Concentration Value
- 7D Qty = Weekly Average Loading Value
- 30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform this office, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5416 or nick.hammer@epa.ohio.gov.

Sincerely,

A handwritten signature in blue ink that reads "Nicholas G. Hammer". The signature is written in a cursive style.

Nicholas G. Hammer
Environmental Specialist
Division of Surface Water

NH/dh

c: Dave Thomas, Director, EORWA
c: Mike Dobbs, Operations Manager, EORWA