



John R. Kasich, Governor
 Mary Taylor, Lt. Governor
 Scott J. Nally, Director

February 5, 2013

Re: Jefferson County
 Barbers Hollow "M" Plant
 NPDES Permit OPH00000*HD
 Correspondence (PWW)

Jefferson County Water & Sewer District
 P.O. Box 2579
 Wintersville, Ohio 43953

Notice of Violation - Significant Non-Compliance

We have received self-monitoring reports covering January through December 2012 for the referenced facility. Our review indicated the following violations of the conditions of your NPDES permit.

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	50060	Chlorine, Total Residual	1D Conc	0.038	.06	6/27/2012
001	00400	pH	1D Conc	6.5	6.3	7/10/2012
001	00400	pH	1D Conc	6.5	6.	7/11/2012
001	00300	Dissolved Oxygen	1D Conc	5.0	3.	7/27/2012
001	80082	CBOD 5 day	7D Qty	36	38.8295	9/1/2012
001	50060	Chlorine, Total Residual	1D Conc	0.038	.2	9/17/2012
001	50060	Chlorine, Total Residual	1D Conc	0.038	.06	10/9/2012
001	50060	Chlorine, Total Residual	1D Conc	0.038	.2	10/30/2012

Please provide non-compliance notification pursuant to the permit requirements. The permit requires the Owner to report non-compliance as directed by Part III.12.E which shall contain information listed in Part III.12.B and Part III.12.C. Please review the requirements for reporting non-compliance and provide the appropriate correspondence.

If you have any questions, please feel free to contact me at (740) 380-5272.

Sincerely,

Aaron Pennington
 District Representative
 Division of Surface Water

AP/dh