



John R. Kasich, Governor  
 Mary Taylor, Lt. Governor  
 Scott J. Nally, Director

February 5, 2013

Re: Jefferson County  
 Granatir Apartment MHP  
 Ohio EPA Permit 0PW00011\*GD  
 Correspondence (PWW)

Mr. Andrew Granatir, Owner  
 943 Efts Lane  
 Wintersville, Ohio 49953

**Notice of Violation – Significant Non-Compliance**

Dear Mr. Granatir:

We have received self-monitoring reports covering May through December 2012 for the referenced facility. Our review indicated the following violations of the conditions of your NPDES permit.

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Conc	12	15.	5/1/2012
001	00530	Total Suspended Solids	30D Qty	0.27	.28388	5/1/2012
001	50060	Chlorine, Total Residual	1D Conc	0.038	.09	5/4/2012
001	00530	Total Suspended Solids	30D Conc	12	21.	7/1/2012
001	00530	Total Suspended Solids	30D Qty	0.27	.39743	7/1/2012
001	00530	Total Suspended Solids	1D Conc	18	21.	7/25/2012
001	00530	Total Suspended Solids	30D Conc	12	14.	8/1/2012
001	00530	Total Suspended Solids	30D Conc	12	16.	9/1/2012
001	00530	Total Suspended Solids	30D Qty	0.27	.3028	9/1/2012
001	00530	Total Suspended Solids	30D Conc	12	15.	10/1/2012
001	00530	Total Suspended Solids	30D Qty	0.27	.28388	10/1/2012
001	00530	Total Suspended Solids	30D Conc	12	17.	11/1/2012
001	00530	Total Suspended Solids	30D Qty	0.27	.32173	11/1/2012
001	00530	Total Suspended Solids	30D Conc	12	17.	12/1/2012
001	00530	Total Suspended Solids	30D Qty	0.27	.32173	12/1/2012

Ohio EPA received correspondence that detailed sand being replaced in the sand filters. Total Suspended Solids have remained out of compliance since the replacement.

Ohio EPA has not received non-compliance notifications for the 2012 violations since sand replacement. Please provide a written followup containing the non-compliance notification required by Part III.12.E which shall contain information listed in Part III.12.B and Part III.12.C. A form is attached that may be used for the non-compliance notification.

Failure to comply with permit conditions may lead to enforcement. **Please respond in writing by March 1, 2013 identifying what corrective measures are being taken to achieve compliance.**

If you have any questions, please feel free to contact me at (740) 380-5272.

Sincerely,

A handwritten signature in blue ink, appearing to read 'A. Pennington', with a large loop at the top.

Aaron Pennington  
District Representative  
Division of Surface Water

AMP/dh

c: Walt Kubat, Wastewater Solutions of Ohio, LLC