



John R. Kasich, Governor  
 Mary Taylor, Lt. Governor  
 Scott J. Nally, Director

February 5, 2013

RE: STARK COUNTY  
 PIKE TOWNSHIP  
 FOHL VILLAGE MHP  
 2500 FOHL ROAD  
 NPDES NO: 3PV00080

Mr. Rick Noca  
 Simco Management Corporation  
 709 Trumbull Avenue  
 Girard, OH 44420

Dear Mr. Noca:

On January 10, 2013, a compliance evaluation inspection (CEI) was conducted by this writer of the wastewater treatment plant serving the above referenced facility. Present during the inspection was Mike Kinnerson, Fohl Village MHP.

At the time of the inspection, the mixed liquor in the aeration tank had a good brown color, indicative of a properly operating biological system. The rapid sand filters were in good operational condition and the treatment plant was producing a clear effluent.

A review of your Discharge Monitoring Reports (DMRs) covering the period January 2009 through December 2012 revealed the following effluent violations:

Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00080*DD	January 2009	001	Total Suspended Solids	30D Qty	6.0	204.862	1/1/2009
3PV00080*DD	January 2009	001	Nitrogen, Ammonia (NH3)	30D Qty	1.7	3.42062	1/1/2009
3PV00080*DD	January 2009	001	CBOD 5 day	30D Qty	5.0	478.556	1/1/2009
3PV00080*DD	January 2009	001	Total Suspended Solids	7D Qty	8.9	817.736	1/8/2009
3PV00080*DD	January 2009	001	Nitrogen, Ammonia (NH3)	7D Qty	2.5	13.6348	1/8/2009
3PV00080*DD	January 2009	001	CBOD 5 day	7D Qty	7.4	1908.69	1/8/2009
3PV00080*DD	April 2009	001	Total Suspended Solids	7D Qty	8.9	17.5226	4/1/2009
3PV00080*DD	April 2009	001	CBOD 5 day	30D Qty	5.0	24.6294	4/1/2009
3PV00080*DD	April 2009	001	CBOD 5 day	7D Qty	7.4	104.818	4/1/2009
3PV00080*DD	October 2010	001	CBOD 5 day	30D Conc	10	10.75	10/1/2010

The NPDES permit for your waste water treatment plant expired July 31, 2012. Ohio EPA has not received a renewal application. Discharging to waters of the state without an active NPDES permit is a violation of ORC 6111 and is subject to escalated enforcement. The renewal application forms may be obtained from the Ohio EPA website <http://www.epa.state.oh.us/dsw/permits/npdesform.html>.

FOHL VILLAGE MHP  
FEBRUARY 5, 2013  
PAGE 2 OF 2

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,

A handwritten signature in black ink, appearing to read "Todd Surrena", written over a light blue horizontal line.

Todd Surrena  
Engineering Geologist  
Division of Surface Water

TMS/cs

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Fohl Village MHP