



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

August 20, 2012

Danny Maag
JD Equipment Inc.
1662 US 62 SW
Washington CH, OH 43160

**Re: JD Equipment Inc.- Washington CH, Fayette County
Industrial Storm Water Permit #4GR00572*DG**

Dear Mr. Maag:

This letter is written regarding a storm water inspection that I conducted at your facility on August 7, 2012, located at 1662 US 62 SW, in Washington Court House, Ohio. The inspection was conducted in order to determine compliance with your industrial storm water general permit. The following items were noted during the inspection, also please see attached pictures:

1. The dike around your wash pad was not containing the wash water. Please revise the design of the wash pad to prevent wash water from discharging outside of the contained area. The berm may not be high enough to collect all of the wash water. The berm also had several channels cut into it which need to be filled-in. There was excessive sediment and debris just outside of the contained area. Please see attached picture.
2. Please conduct monthly and annual inspections per your storm water pollution prevention plan.
3. Please have the alarm installed on the inside wash bay holding tank. Also, as mentioned during the inspection, wash water from the inside bay should not discharge outside. A berm may need to be installed if wash waster does start to discharge outside.
4. The sediment and sludge removed from the outside was pad was disposed of by dumping in the solid waste trash. As mentioned during the inspection, please be aware that the moisture content may be too high to go to a landfill. Also, you will want to discuss the elevated metals limits with your hauler/landfill to determine if the metal levels are too high in the sediment to take to the landfill.

Danny Maag
JD Equipment Inc.
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,

A handwritten signature in black ink, appearing to read 'G L Sanders', written in a cursive style.

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Terry Atherton, JD Equipment Inc.

ec: Greg Sanders, DSW/CDO

GS/nsm JD Equipment, Inc. LLC, August 7, 2012



