



John E. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 20, 2012

Jeff Kaurez
Autozone Inc
123 S Front Street
Memphis, TN 38103

**Re: Pre-Construction Storm Water Inspection at Autozone in Pataskala
Permit #: 4GC03865*AG**

Dear Mr. Kaurez:

This letter is written regarding a storm water inspection I conducted at Autozone located Pataskala, Ohio on December 17, 2012. Ohio EPA has received and approved this site for coverage under the General Storm Water Permit associated with Construction Activities. Based on my site observations, the following items were noted:


- **Sediment Controls:** The site was recently disturbed and the surrounded by silt fence. Please ensure the silt fence is maintain through your required weekly inspections or within 24 hours of a rain event equal to or greater than 0.5 inches
- **Erosion Control Requirements:** Please be aware the General Permit mandates specific permanent and temporary stabilization requirements. All disturbed areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. All areas of final grade must be protected within seven days. All earth disturbing activities should be clearly logged in your inspection reports to ensure the 21 day / seven day requirement is not violated. ***The site was stabilized with a temporary cover in preparation for the winter months***
- **Maintenance Requirements:** The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review. All earth disturbing activities must be clearly documented in your inspection reports to ensure the temporary or permanent stabilization requirements are not violated.

Jeff Kaurez
Autozone Inc.
Page 2

- **Post Construction Requirements:** The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office