



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 19, 2012

Norm Murphy
JD Equipment Inc.
4000 Gantz Road, Suite A
Grove City, Ohio 43213

**Re: Industrial Storm Water Inspection at JD Equipment in London Ohio,
Permit Number 4GR000573*DG**

Dear Mr. Murphy:

This letter is written regarding a storm water inspection I conducted at JD Equipment located in London, Ohio on December 17, 2012. The purpose of the inspection was to evaluate compliance with the Multi Sector General Storm Water Permit associated with Industrial Activities found at http://www.epa.ohio.gov/dsw/permits/GP_IndustrialStormWater.aspx. The following items were noted:

Storm Water Pollution Prevention Plan (SWPPP):

- This facility is currently covered under the recently renewed Multi Sector General Storm Water Permit. The SWPPP must be updated in accordance with the specific sector requirements within 180 days from the date of renewal.
- Please understand there are sector specific requirements which must be inclusive in your site specific SWPPP. Please refer to the link above regarding the sector specific requirements for this site.


Site Observations:

- A large wash pad is established in the rear of the facility which directs all wash water to an oil water separator with a final treated discharge to Madison County Waste Water Treatment Plant. However, on the day of the inspection I noted washing activities outside of the containment area resulting in a direct violation of your Storm Water Permit (SEE ATTACHED PHOTO). Please submit a formal response (email preferred to harry.kallipolitis@epa.state.oh.us) regarding the violation and the corrective actions taken to ensure this violation will NOT re-occur.
- Please be able to demonstrate the fuel tanks are dual walled. Please note, in the event accumulative storage of fuel exceeds 1320 gallons, a Spill Prevention Control and Countermeasures (SPCC) is required. Please indicate in your response letter the amount of fuel storage.

- A secondary containment pad for purposes of fueling should be established.
- Please provide a record (one year) of the clean outs associated with the oil water separator and demonstrate location of final disposal and connection to the regional sanitary sewer system.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office



Figure 1: Washing Activities outside washpad