



February 8, 2013

Tim Muckley
Glitz and Associates Inc.
4835 Munson St. NW
Canton, OH 44718

**Re: Storm Water Inspection at The Shoppes at East Broad / Fairfield County
Permit Number: 4GC02248*AG**

Dear Mr. Muckley:

This letter is written in follow up to a construction storm water inspection I conducted at The Shoppes at East Broad along Broad Street in Reynoldsburg, Ohio on January 24, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following was noted:

Regional Water Quality Basin

- The regional water quality basin located on the extreme western edge of the site incorporates a drain way which was previously eroded. This drain way was repaired as requested, however, based on my site observations, the erosive flows continue and additional stabilization measures are expected to ensure a significant erosion gulley does not reoccur.

Stream Restoration

- The stream restoration project is not established, I am unable to terminate the permit coverage as a result of this issue. In addition, several of the lots remain undeveloped. Additional restoration efforts are expected this spring. Mature trees are recommended.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. A follow up inspection will be conducted to ensure the conditions of the General Permit are met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Shoppes at East Broad 1-24-2013