



John T. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Farley, Director

February 8, 2013

Steve Peck
Dominion Homes
5000 Tuttle Crossing Boulevard
Dublin, OH 43016

**Re: Storm Water Inspection at Reynolds Crossing, Section 2 / Franklin County
Permit #: 4GC03549*AG**

Dear Mr. Peck:

This letter is written in follow-up to a construction storm water inspection I conducted at Reynolds Crossing Section 2 located in Reynoldsburg, Ohio on January 24, 2013. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following items were noted:

Sediment and Erosion Controls:

- Construction activities are ongoing for this site. Give the scope of work, a sediment basin is now expected. I am unaware of any of the pre-existing ponds from the previous sections are currently utilized for sediment control. Please advise in your response or demonstrate an approvable alternative.
- All perimeter controls, specifically on the western edge of Phase 2 require maintenance.

Post Construction:

- Please indicate in your response what post construction measures are utilized for this section.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Reynolds Crossing Sec. 2 1-24-2013